

**PROFORMA FOR SAFE DRINKING WATER AND
SANITARY CONDITION CERTIFICATE**

No. 018

Dated: 19/03/26

It is certified that an inspection team headed by Amit Yadav (M.O.)
(Name of Officers with designation) from Assistant Engineer PHED inspected
the PSD International School, Meghrajpur (Name & Address of
the school) on 18/03/2026 (date of inspection) and on the basis of Water Test Report
(Attached) bearing no. 135/03 dated 19/03/26 of
Meerut PHED (PHED Lab) certified that the
PSD International School (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 18/03/2027

अधिकारी अभियन्ता (मु०)
जलकल विभाग
नगर निगम मेरठ

Signature with Seal: Amit YadavName: Amit YadavDesignation: Asst. Eng. PHED

Name & Address of the Office / Department:

Meerut division

To

The principal
PSD International School, Meghrajpur
(Name & Address of the Institution) Meerut

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



कार्यालय अधिकारी अभियन्ता (मु०)
जलकल विभाग-नगर निगम मेरठ
पत्र सं० 135/03 मु० ज० क० मेरठ
दिनांक 17/03/26

JAL KAL VIBHAG NAGAR NIGAM MEERUT CHEMICAL ANALYSIS LABORATORY

REPORT NO. DW/03/LAB2026-57/24

DATE: 17/03/2026

DRINKING WATER ANALYSIS REPORT

1	Name & Address	PSD INTERNATIONAL SCHOOL, MEGHRAJ PUR, MEERUT
2	Sample Collected By	By SUMIT
3	Nature of Sample	Drinking Water
4	Date of Sample Collection	12/3/2026
5	Date of Sample Receiving	12/3/2026
6	Date of Analysis Completed	17/03/2026

Sr.N.	PHYSICAL PARAMETERS	UNITS	OBSERVED VALUE	STANDARDS (IS 10500 - 2012)	
				DESIRABLE LIMIT	PERMISSIBLE LIMIT
1	COLOUR, UNITS	-	COLOURLESS	-	-
2	ODOUR	AGREEABLE	ODOURLESS	AGREEABLE	-
3	TEMPERATURE	Oc	30.1	-	-
4	TURBIDITY	ntu	0.5	5	10
5	CONDUCTIVITY AT 25° C	µmho/cm	128.0	-	-

CHEMICAL PARAMETERS

6	Ph	-	7.5	6.5 to 8.5	No Relaxation
7	Suspended Solids	mg/l	Nil	-	-
8	Dissolved Solids	mg/l	62.0	500	2000
9	Total Solids	mg/l	62.0	-	-
10	Total Alkalinity (as CaCO ₃)	mg/l	40.2	200	600
11	Total Hardness (as CaCO ₃)	mg/l	72.4	200	600
12	Chlordies (as Cl)	mg/l	41.0	250	1000
13	Fluoride (as f) mg/l	mg/l	Nil	1.0	1.5
14	Nitrate (as NO ₃)	mg/l	0.21	45.0	100.0
15	Iron (Fe)	mg/l	Nil	0.3	1.0

BACTERIOLOGICAL PARAMETERS

16	Total Coliform	MPN/100 ml	Absent	Absent	-
17	E.Coli	MPN/100 ml	Absent	Absent	-

*Note : The Water is Suitable for drinking purpose.

Analyst

Laboratory In-charge

JE (HQ)

अधिकारी अभियन्ता (मु०)
जलकल विभाग
नगर निगम मेरठ

NOTE:- 1. The above result are related only to the test performed on the sample

2. This report is not to be reproduce wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.

3. Sample will be destroyed in the after fifteen days from the date of reporting.